

certificate  
no. **BAU 14038**  
dated 2014-02-14

Translation

## EuroTest Certificate

Name and address of the holder of the certificate: (customer) SBH Tiefbautechnik GmbH  
Ferdinand-Porsche-Str. 8  
52525 Heinsberg

Product designation: **Margin-supported trench shoring system, made of aluminium**

Type: 250er series

Testing based on: DIN 4124: October 2002  
DIN EN 13331: November 2002

Test report: Hegger und Partner G08-80

Further details: Permissible earth pressure loading 26,5 kN/sqm  
for panel lengths of up to 2,00 m  
Permissible earth pressure loading 21,6 kN/sqm  
for panel lengths of up to 2,50 m  
Permissible earth pressure loading 17,5 kN/sqm  
for panel lengths of up to 3,00 m  
Consequence certificate for the number: 09036-GS

The manufacturer is also Certificate holder

The type tested complies with the test basis specified above.

The holder of the certificate is entitled to affix the ET-mark shown overleaf to the products complying with the type tested.

The present certificate including the right to affix the ET-mark is valid until: **2019-02-13**

Further provisions concerning the validity, the extension of the validity and other conditions are laid down in the Rules of Procedure for Testing and Certification of August 2012.

  
Dipl.-Ing. Kurt Hey  
Certifikation



In any case, the German original shall prevail

